

PAGE: 1

PRINT DATE: 6/5/95

**FAILURE MODES EFFECTS ANALYSIS (FMEA) – CRITICAL HARDWARE**

NUMBER: 05-GWA-2086HA-X

SUBSYSTEM NAME: EPD&C-WATER SPRAY BOILER

REVISION: 1 07/26/94

---

	<b>PART NAME VENDOR NAME</b>	<b>PART NUMBER VENDOR NUMBER</b>
LRU	: PANEL R2	V070-730277
SRU	: RESISTOR	RWR8081211FR

---

**PART DATA**

---

**EXTENDED DESCRIPTION OF PART UNDER ANALYSIS:**

RESISTOR IS 1.2K OHMS, 2 W, BETWEEN LOGIC POWER BUS AND PANEL TOGGLE SWITCH FOR WSB CONTROLLER "A" LOGIC CIRCUIT.

**REFERENCE DESIGNATORS:** 32V73A2A20R1

32V73A2A17R1

32V73A2A21R1

32V73A2A18R1

32V73A2A22R1

32V73A2A19R1

**QUANTITY OF LIKE ITEMS: 6**

SIX, TWO PER WATER SPRAY BOILER SYSTEM

**FUNCTION:**

LIMITS LOGIC CIRCUIT CURRENT FOR THE REMOTE POWER CONTROLLER'S (RPC) POWERING CONTROLLER "A" OF WATER SPRAY BOILER SYSTEMS 1, 2 AND 3, AND WSB INLET LINE HEATER.

**FAILURE MODES EFFECTS ANALYSIS (FMEA) – NONCRITICAL FAILURE MODE**  
**NUMBER: 05-6WA-2086HA-01**

REVISION# 05/25/95

SUBSYSTEM NAME: EPD&C-WATER SPRAY BOILER

LRU: PANEL R2

ITEM NAME: RESISTOR

CRITICALITY OF THIS

FAILURE MODE: 1R3

**FAILURE MODE:**

OPEN

**MISSION PHASE:**

LO LIFT-OFF

DO DE-ORBIT

**VEHICLE/PAYLOAD/KIT EFFECTIVITY:** 102 COLUMBIA  
 103 DISCOVERY  
 104 ATLANTIS  
 105 ENDEAVOUR  
 EFFECTIVE FOR WSB INLET LINE ELECTRICAL  
 HEATER MOD ONLY

**CAUSE:**

STRUCTURAL FAILURE (MECHANICAL STRESS, VIBRATION), ELECTRICAL STRESS,  
 THERMAL STRESS, PROCESSING ANOMALY

CRITICALITY 1/1 DURING INTACT ABORT ONLY? NO

**REDUNDANCY SCREEN** A) PASS  
 B) PASS  
 C) PASS

**PASS/FAIL RATIONALE:**

A)

B)

C)

**CORRECTING ACTION:**

ASCENT - SHUT DOWN AFFECTED APU/HYD SYSTEM AT AN APPROPRIATE TIME BASED  
 ON FLIGHT PHASE AND SYSTEM TEMPERATURE.

ENTRY - SHUT DOWN AFFECTED APU/ HYD SYSTEM OR DELAY APU START IF FAILURE  
 IS KNOWN PRIOR TO DEORBIT.

THE FOLLOWING OPERATIONAL USE APPLIES TO NORMAL MISSIONS (NO FAILURES):  
 SWITCH TO "B" SIDE 24 HOURS AFTER ORBITAL INSERTION.

**REMARKS/RECOMMENDATIONS:**

THIS FAILURE MODE WAS NOT ASSESSED FOR CRITICALITY 1R2 DURING INTACT ABORT  
 ONLY (AVIONICS ONLY) SINCE REDUNDANCY REQUIREMENTS HAVE BEEN MAINTAINED  
 PER NSTS 22206, PARAGRAPH 3.2.C.2.

PAGE: 3

PRINT DATE: 06/01/95

## FAILURE MODES EFFECTS ANALYSIS (FMEA) - NONCRITICAL FAILURE MODE

NUMBER: 05-6WA-2086HA-01

---

**- FAILURE EFFECTS -**

---

**(A) SUBSYSTEM:**

LOSS OF POWER TO CONTROLLER 'A' AND INLET WATER LINE HEATER OF ASSOCIATED WATER SPRAY BOILER.

**(B) INTERFACING SUBSYSTEM(S):**

LOSS OF LINE HEATER WILL CAUSE WSB SPRAY BAR FREEZE UP AND SUBSEQUENT LOSS OF COOLING CAPABILITY, RESULTING IN LOSS OR LIMITED RUN TIME OF ONE APU/HYD SYSTEM. LIMITED RUN TIME MAY NOT ALLOW AFFECTED APU/HYD SYSTEM TO SUPPORT AN ABORT SCENARIO OR HOT APU RESTART FOR IMMEDIATE RETURN.

**(C) MISSION:**

NO EFFECT - FIRST FAILURE. WSB SPRAY BAR FREEZE-UP SUBLIMATES IN 3 HOURS MAX.

**(D) CREW, VEHICLE, AND ELEMENT(S):**

NO EFFECT - FIRST FAILURE

**(E) FUNCTIONAL CRITICALITY EFFECTS:**

FUNCTIONAL CRITICALITY EFFECTS FOR OPEN RESISTOR: LOSS OF CONTROLLER 'A', AND LINE HEATER. SECOND FAILURE: LOSS OF REDUNDANT CONTROLLER 'B' IN SAME WSB WILL CAUSE LOSS OF WSB. THIRD FAILURE: LOSS OF CREW/VEHICLE WITH LOSS OF SECOND APU/HYD SYSTEM.

FUNCTIONAL CRITICALITY EFFECTS FOR LOSS OF HEATER: CRITICALITY 1R2 FOR RTLS, TAL, AOA ABORTS, AND IMMEDIATE RETURN (HOT APU RESTART): LOSS OF WSB DUE TO FREEZING OF SPRAY BAR WILL CAUSE LOSS OF ONE APU/HYD SYSTEM. LOSS OF A SECOND APU/HYD SYSTEM WILL RESULT IN LOSS OF CREW/VEHICLE.

---

**- APPROVALS -**

---

PRODUCT ASSURANCE ENGR : T. K. KIMURA  
DESIGN ENGINEERING : G. J. SCHWARTZ: J. Kimura 6/1/95  
: G. J. Schwartz 6-1-95