

Critical Item: Master Scanner
Find Number: 78K01367 1 ea.
Criticality Category: 1B

SYSTEM	AREA	CRIT	TOTAL LRU'S
Hypergol Vapor Detection System	LOA	1B	1
Fixed Hydrogen Leak Detection System (FCSS)	LOA	1B	SHARED

SAA No:	09IT09-001	System/Area:	LPS/DCMS/FR1/FR2/CR3/CR4
NASA Part No:	78K01367	PMN/Name:	L72-0S00-01A CDBFR
Mfg/Part No:	78K01367	Drawing/Sheet No:	MCR7658 VOL.11 3.2(REV EW)

Function: This CDBFR Critical Item is used in support of a critical user system. It provides all synchronizing & clock signals for CDBFR operations.

Critical Failure Mode/Failure Mode No: * Failure Mode - Loss of output/09IT09-001.470; * Failure Mode - Erroneous Output/09IT09-001.471

* Master Scanner failures could result in loss of computer communications with a single chassis, multiple chassis or entire CDBFR causing CPU failures resulting in loss of data path for the critical system being monitored/controlled.

Failure Cause: Electrical/Electronic failure of LRU piece part

Failure Effect:

SYSTEM	FAILURE EFFECT	CRIT
Hypergol Vapor Detection System (LOA)	Loss of output signal will fail to provide the console operator with an input that would indicate a leak in the hypergol propellant servicing system. Loss of the capability to detect a leak during hazardous operations could result in loss of life and/or vehicle. Detection method: System status checks will detect failure. Time to effect: Immediate.	1B
Fixed Hydrogen Leak Detection System (FCSS)(LOA)	System would fail to indicate a hydrogen leak. Could allow loss of life or vehicle during hazardous conditions. Detection method: System status checks will detect failure. Time to effect: Immediate.	1B

Master Scanner (Continued)

ACCEPTANCE RATIONALE

Design: The Master Scanner was designed per the requirements of the following documents.

1. OP09IT0910: General design requirements specification for LPS/CCMS.
2. CP09IT0914: Contract end item assembly specifications for CDBFR for LPS/CCMS.

Error condition (inoperative) is easily detectable by software, it notifies user according to nature of problem.

Test: Rigorous sets of acceptance tests were performed to verify performance and design requirements of the LPS/CCMS. This process occurred on each end item from "In Process Assembly" phase to "Site Acceptance". Master control procedures (MCPs) 78K-M401 and 78K-M701 were utilized for acceptance testing by MMC. Following this acceptance testing IBM performed integrated testing of each set. Test procedures K8C-LPS-IB-086, Book 3 and K8C-LPS-IB-105, Book 5 were utilized.

Hypergol Vapor Detection System

- OMRSD File VI, Volume 1, Baseline 12/13, "LOA MMVH204 Servicing System", requires a sensor functional test prior to each flow. OMI V3542 "Hypergol Vapor Detection System Operations Support (LPS)" provides this end-to-end verification of the system (LPS/HVDS).
- During loading operations, personnel are stationed on the RSS to provide visual monitor.

Fixed Hydrogen Leak Detection System (FCSS)(LOA)

- OMRSD File VI, Volume 1, Baseline 10, "LOA Fuel Cell Servicing System, LH2/GH2", requires Leak Detector and LPS Function Designator end-to-end tests prior to each flow. OMI V3541 "Remote Hydrogen Leak Detection System Operational Support (LPS)" provides this end-to-end test.

Inspection: LPS system integrity is continuously monitored by on-line software programs. These programs provide health and status to system operators. OMRSD, File VI requires inspection and power adjust/verification every 90 days. CDBFR stress test is performed every 180 days and card edge connector cleaning 1800 days. OMI's, C6030 "Common Data Buffer Assembly PM" and C2030 "Common Data Buffer Stress Test" satisfy these requirements.

Failure History:

The PRACA Data Base was used for this analysis (timeframe APR. 88 to Sep. 90). There were 2 Problem Reports initiated on Master Scanner Cards that relate to failure modes depicted on this CIL sheet. There is a total population of 17 Master Scanners installed in various CCMS Station Sets. In the basic SAA (timeframe of Jan. 84 to Mar. 88) was used with 13 Problem Reports identified from a total population of 13 cards installed. Operation use varies from 7 days a week, 24 hours a day to as required.

SAAD81T09-001
REV. A

CIL 199701
Attachment 3
Sheet 13 of 19

SEP 25 1997

Master Scanner (Continued)

Operational Use:

• Correcting Action:

Switch CDBFR functions to spare CDBFR or troubleshooting required to isolate and replace failed unit.

• Timeframe:

60 minutes