

NAME P/R QTY	CRIT	FAILURE MODE & CAUSES	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
FAN/SEPARATOR/PUMP/ MOTOR ASSEMBLY, ITEM 123 SU787994-B (1)	2/1R	123PMB1: Restricted vent flow. CAUSE: Contamination build up on the fan rotor surfaces or in the valve housing passage.	END ITEM: Loss of or reduction in vent flow to the helmet. GPE INTERFACE: Reduction in CO2 and moisture removal capability. Increase in suit temperature, humidity and CO2 level. Possible freeze-up of the sublimator (item 140) coolant passages. MISSION: Terminate EVA. Possible loss of use of one EMU. CREW/VEHICLE: None for single failure. Possible loss of crewman with loss of vent flow sensor output or SOP.	A. Design - Particulate contamination in the ventilating gas of the EMU shall not exceed 0.1 mg/m3 and the CCC, Item 480, provides this filtration level. B. Test - Component Acceptance Tests - A performance test is performed at "EVA" and "EVA" conditions to verify the integrity of the fan. At "EVA" the fan inlet pressure is set to 3.89 - 3.95 psia, with a flow rate of 4.27-6.57 ACFM O2, the differential pressure across the fan must be a minimum of 3.22 inches H2O. At "EVA" the fan inlet pressure is set to 18.35-18.6 psia, with a flow rate of 7.13-7.33 ACFM O2, the differential pressure across the fan must be a minimum of 13.56 inches H2O. The item is subjected to a burn-in cycle test where it must operate for 24 hours. It is cycled 3 times at 3 hours "EVA" and 5 hours "EVA" conditions. The item performance is tested again in the "EVA" condition, as per above. CEI PDA Test - The item is cycled (on for two 12) hours, then off) ten (10) times in the EVA mode to give 20 hours minimum of run time. The item is then performance tested in the EVA and PRESS modes. At EVA the fan outlet pressure is 0.4-1.4 psig and a flow of 6.72 ACFM O2, the differential pressure across the fan must be a minimum of 3.56 inches H2O. At PRESS the fan outlet pressure is 4.2-4.4 psig and a flow of 6.5 ACFM O2, the differential pressure across the fan must be a minimum of 3.56 inches H2O. The test fixtures and interfacing hoses are cleaned to MS150 EN50A. The test facility O2 circuit is cleaned to MS3150 EN50A. Certification Test - The item completed 10,000 hours of operation and 8,400 on/off cycles exceeding the 15 year certification requirement by more than a factor of three. The 15 year structural vibration, electrical vibration, and design shock was completed 12/84. The following engineering changes have been incorporated and certified since this item's certification: 42806-342-25 (change power consumption requirement - more amps), 42806-406 (incorporate Nitronic 60 Retaining Nut), 42806-424 (seal clip change to assure a good

CIL
EMU CRITICAL ITEMS LIST

12/24/91 SUPERSEDES 01/02/90

ANALYST:

Page: 2
Date: 12/12/91

NAME P/N QTY	CRIT	FAILURE MODE & CAUSES	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
--------------------	------	-----------------------------	----------------	--------------------------

2/1R 123FHD1:

Wld), 42806-816 (water pump changes inspection in areas that are susceptible to contamination, move breakage and deburring operations to close RPR J-EMU-123-010), 42806-934 (change bearing limited life requirement).

C. Inspection -

Fan rotor, volute housing and fan end of motor housing are cleaned to H3750 EN1508 prior to assembly. Volute positioning procedure centers the volute around the fan rotor and aligns volute away from fan rotor to proper height to provide maximum clearance all around rotor of .037" min. (HSD NIP on this operation). During balance of relative assembly and subsequent studding and cleaning of fan rotor, the item is mounted in a rig cart which provides a positive pressure of R2 gas through the bearings, around the fan and out the volute horn to prevent entrance of contaminants. A NIP'd operation just prior to inprocess testing verifies that all assembled details were cleaned to prescribed cleanliness levels. (i.e., cleaning slips are verified for all details). An IPI is performed to verify base point specifications for fan flow in both the EVA and IVA modes. If fan flow is found to be out of spec, an operation is provided for reworking of the volute. The item is packaged to maintain cleanliness at all times.

D. Failure History -
None.

E. Ground Turnaround -

Tested per FEMU-R-001, Water Servicing leakage and Gas Removal Test, Para. 7.3.3.2.1,1.2.

F. Operational Use -

Crew Response
Pre EVA: Trouble-shoot problem, if no success consider EMU 3 if available. EMU go for SCV ops without fan.
EVA: When CMS data confirms loss of ventilation flow, terminate EVA.
Training

CIL
EMI CRITICAL ITEM LIST

12/24/91 SUPERSEDES D1/02/90

ANALYSE:

Page: 3
Date: 12/12/91

NAME P/N QTY	CRFT	FAILURE MODE & CAUSES	FAILURE EFFECT	RAISONNE FOR ACCEPTANCE
	2/1R	1231HD1:		Standard EMI training covers this failure mode. Operational Considerations Flight rules define go/no go criteria related to ventilation, flow and O2 control. Flight rules define EMI go to remain on SCU (available for rescue if required). EVA check/ret procedures verify hardware integrity and system operational status prior to EVA. Real time O2 air System allows ground monitoring of EMI systems.