CIL EMII CRITICAL ITEMS LIST

Page 1

EMU CRITICAL ITEM	S LIST	5/30/2002 SUPERSEDES 12/24/1994			Date: 3/27/2002
NAME P/N QTY	CRIT	FAILURE MODE & CAUSES	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE	
		137FM02A			. – – – – – – – –
WATER SHUTOFF VALVE, ITEM 137 	2/2	Fails open. Electrical open in the solenoid coil or electrical connector; poppet jams due to contamination; spring fractures; failure of electronic switch (diode resistor, or transistor opens or shorts).	END ITEM: Unable to place the sublimator "off-line" at the end of the EVA mission or shut off feedwater supply during EVA. GFE INTERFACE:	A. Design - The valve seat is protected by a 140 micron nominal inlestressed, has infinite life at small stroke of valve. The module is fabricated using "S" level reliability passive level semi-conductors. B. Test - Vendor Acceptance Test (Kaiser-Eckel Valve Co.) - Performance testing per Vendor Acceptance Procedures will circuits and any failure to components of the electrical meet the voltage stabilization, response, or current dragof the poppet and/or spring fracture would be noted during the stabilization of the second stabilization.	The electronics drive e components and JANTXV ll detect electrical open l switch by failure to aw requirements. Jamming
			Water leakage to ambient through sublimator. MISSION: Loss of EMU.	Vendor Acceptance Tests. PDA Test - A combined water circuits leakage test is run per SEMU-water circuits are pressurized to 15.7-15.9 psig with water minimum. Leakage must not exceed 6 scc/hr. Certification Test - Certified for a useful life of 20 years (ref. EMUM-1030)	ater for 60 minutes
			CREW/VEHICLE: None. TIME TO EFFECT /ACTIONS: Minutes. TIME AVAILABLE: N/A	C. Inspection - Poppet jams open due to contamination. A cleanliness le maintained during assembly and testing of the valve. A located at both the valve inlet and outlet to protect th contamination. Electrical related failures. All external lead wires as are inspected during source inspection and again during Fractured spring. A vendor acceptance test for performs failure of this nature.	evel of HS3150 EM150 is 140 micron filter is he valve from ssociated with the item PLSS assembly.
			TIME REQUIRED: N/A REDUNDANCY SCREENS: A-N/A B-N/A C-N/A	D. Failure History - EMU-137-D002 (1/18/79) Unable to actuate valve to closed position due to contar lubricating the external "O" seals revised, as well as operations. EMU-137-C001 (3/10/79) Cause and corrective action are the same as EMU-137-D002	cleaning and drying

EMU-137-C002 (3/10/79) Cause and corrective action the same as EMU-137-D002.

B-EMU-137-A001 (8/10/92) - Item 137, Shut off valve failed open when the feedwater valve switch was off. The failure could not be reproduced. No corrective action taken.

B-EMU-137-A002 (7/23/00) - Numerous water droplets found around Sublimator and

EMU CRITICAL ITEMS LIST

5/30/2002 SUPERSEDES 12/24/1994
Date: 3/27/2002

NAME FAILURE

P/N MODE & QTY CRIT CAUSES FAILURE EFFECT RATIONALE FOR ACCEPTANCE

Porous Plate while performing item #135 Valve relief and reset check & 132 A 7 B calibration procedure P528/SEMU-636/Y, Step 2.1. Discrepancy exists against the #137 Feedwater shutoff valve. Supplier (Kaiser) manufacturing process introduced contaminants. Corrective actions previously implemented (ref. H-EMU-137-D006) against Kaiser after manufacture of this valve.

Page 2

E. Ground Turnaround -

Tested for non-EET processing per FEMU-R-001, Water Servicing, Leakage and Gas Removal.

None for EET processing.

F. Operational Use -

Crew Response

Pre/Post EVA: When detected perform water dump of feedwater tanks. Consider using third EMU, if available. EMU is go for SCU ops.

EVA: No response, single failure undetectable by crew or ground.

Training

Standard EMU training covers this failure mode.

Operational Considerations -

Flight rules define go/no go criteria related to EMU thermal control. EVA checklist procedures verify hardware integrity and systems operational status prior to EVA. Real Time Data System allows ground monitoring of EMU systems.

EXTRAVEHICULAR MOBILITY UNIT

SYSTEMS SAFETY REVIEW PANEL REVIEW

FOR THE

I-137 FEEDWATER SHUTOFF VALVE

CRITICAL ITEM LIST (CIL)

EMU CONTRACT NO. NAS 9-97150

Prepared by: 15 - Project Engineering

Approved by: 228

MASA Creve

Program Manager