

CIR
CIR CRITICAL ITEM LIST

Page: 1
Date: 09/28/90

09/28/90 SUPERSEDES 07/02/90

ANALYST:

NAME P/N QTY	ITEM #	FAILURE MODE & CRUSA	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
WATER TANK ITEM #40 SV740592-28 113	2/2	160700101 Bladder rupture.	END TIME: None during standby mode. During use, O2 is enriched into the sublimator feedwater and the constant loop.	A. Design: The current bladder material is neoprene latex or diaphragm which exhibits outstanding tensileility, elasticity and elongation characteristics. Bladder processing is controlled to provide uniform product properties. The housing cavity walls consist of smooth surfaces. The bladder is lubricated with controlled quantities of kynar polymer to bladder installation. The valve rails of bladder are approx. 1 which minimizes bladder stretching. The tank structure supports the bladder load when the water pressure is above the gas pressure.
		160700102 Excessive cycling, defective material, lack of Kynar lubricant.	END TIME: Degradation in sublimator performance in proportion to the amount of enriched gas. Possible pump cavitation.	B. Test - Component Acceptance: The item is internally leakage tested per AI-1-131-2 by pressurizing the item #40 inlet to 15.3 - 15.7 psig GOF. The O2 outlet is connected to a hose and the end of the hose submerged in H2O. There shall be no bubbles within a 5 minute period.
		160700103 Terminate O2A during standby water tank operation if cycling is insufficient or lost.	END TIME: None.	A bladder collapse leakage test is performed by pressurizing the O2 side of the bladder to 15.3 - 15.7 psig GOF. With the O2 side of the bladder connected to a hose and outlet of the hose submerged in H2O, the leakage shall be limited to 1 bubble in 1 minute. The pressure is increased to 15.3 - 15.7 psig GOF and the leakage shall be the same. Pressurized time is traced per the linked title List RMU-47-001).
		160700104 None.	END TIME: None.	A bladder collapse leakage test is performed per RMU-58-010 by pressurizing the bladder O2 side to 15.3 - 15.7 psig GOF. With the O2 outlet connected to a hose and the hose submerged in H2O, the leakage shall not exceed 1 bubble in 2 minutes.
				A water circuit leakage test is performed by pressurizing the water circuit to 15.3 - 15.7 psig H2O. The leakage shall not exceed 4 cc/hr as measured with a volumetric micrometer for a 40 minute period.
				Certification: 1. The Neoprene latex bladders completed 11,000 fill/drain cycles during 8/85. This is approx. six times the cycle

P-1
CO

Q-1
D-1
S-1
R-1
E-1
F-1
G-1
H-1
I-1
J-1
K-1
L-1
M-1
N-1
O-1
P-1
Q-1
R-1
S-1
T-1
U-1
V-1
W-1
X-1
Y-1
Z-1

08/01/80 SUPERSEDES 11/10/79

ANALYST:

NAME	FAILURE		
P/D	MODE 6		
QID	CRT	CAUSE	FAILURE EFFECT
	2/2	100%WTA	certification requirement of 1,000 per SSEMU-P11. Engineering changes 42006-BAB (more reliable leakage test) and 42006-BBB (new bladder mfg. process) have been incorporated and certified since this configuration was certified. However, these changes do not pertain to this failure mode.

2. The (flame) bladders completed 4,000 fill/drain cycles
during 3/80, 10/80, and 11/80. (This is two times the 15 year
certification requirements of 1,000 cycles.)

C. Inspection -

The material used to manufacture the bladders is fully
inspected to meet the material specification requirements.

The bladders are 100% dimensionally inspected for outages,
and 100% visually inspected for any surface defects.

A leakage test is run to check every corner of the bladder
for hidden defects. After the corners are checked, a
leakage test is run to check the overall bladder for hidden
defects and leaks. No leakage is allowed for either test.

After the leakage tests, the bladders are 100% visually
inspected for any defects resulting from the leakage tests.

The amount of Krytox applied to the bladders is 100%
inspected to meet the requirements defined by an engineering
approved visual standard.

D. Failure History -
None.

E. Ground Turnaround -
Tested per FIMU-S-004, Reserve to Primary Water Tank
leakage.

F. Operational Use -
Crew Response
EVU: No constraint for single failure. When ODU data
confirms activation of reserve water tank, terminate EVU.

320