

C11
CRITICAL ITEMS 4137
1341: C113/1

NAME P/N QTY	COST	FAILURE MODE & CAUSE	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
OF PRESSURE REGULATOR, 2ND STAGE ITEM 213D SV/778678- 33 100 EC178-1	2/14	<p>ISSUES: INTERNAL GAS LEAKAGE, FAILS OPEN.</p> <p>CAUSE: CONTAMINATION, SEAL FAILURE, BALL RETURN PLUNGER OR ACTUATOR PLUNGER JAMS, STATIC SEAL DEGRADE AT DIAPHRAGM VALVE LIP SEALS OR BALANCE STEM O-RING, BELLOWS FAILURE, LEAKAGE FROM THE SENSING CAVITY TO JUBBERS.</p>	<p>RND ITEM: LIMITS SGP OXYGEN FROM PO SURE.</p> <p>O/E INTERFACE: PRESSURE DEPLETION OF EMERGENCY O2 SUPPLY. ALSO, MAY INCREASE SUIT PRESSURE ABOVE 4.7 PSID WITH 144 CRACKS), UP TO 6.5 PSID MAX. POSITIVE PRESSURE RELIEF VALVE ITEM 144 PREVENTS SUIT OVERPRESSURIZA- TION.</p> <p>MISSION: TERMINATE EVA, LOSS OF USE OF O2 LNO.</p> <p>CRN/VEHICLE: NONE FOR SINGLE FAILURE. POSSIBLE LOSS OF CRUISE WITH LOSS OF PLS.</p>	<p>A. DESIGN - IF THE ACTUATOR PLUNGER JAMS, THE ACTUATOR CANNOT BE FORCED TO BY WHICH MEANS THE SECOND STAGE CANNOT BE BROUGHT ON LINE. THE DIAPHRAGM VALVE AREA IS PROTECTED WITH A 25 MICRON FILTER. SLIDING PARTS ARE HARDER THAN THOSE MATING BONES TO PREVENT GALLING. THE LIP-SEALS HAVE METAL TO METAL FIT ON BOTH SIDES AND THE PRESSURE INCREASES THE LOAD ON THE SENSING LIP. THE BALANCE STEM SEAL IS SIZED TO PROVIDE SQUEEZE UNDER ALL LOAD CONDITIONS. THE BALANCE STEM SEAL HAS A BACK-UP RING ON BOTH SIDES. THE SENSING CHAMBER IS SEALED BY A RADIAL SILICONE O-SEAL. THE DIMENSIONAL CONTROL AND TOLERANCE RIGIDITY OF THE RADIAL CONFIGURATION ASSURE SEALING. THE BELLOWS STRUCTURAL INTEGRITY IS ASSURED BY A 25 PSID PROOF TEST WHICH GIVES A MARGIN OF 5 OVER THE NORMAL OPERATING PRESSURE OF 4.5 PSID. THE BELLOWS AND SPRING ARE DESIGNED SUCH THAT INTERFERENCE WILL NOT OCCUR TO IMPIDE VALVE CLOSING.</p> <p>B. TEST - WINDOW COMPONENT ACCEPTANCE TEST - THE WINDOW, CTE, PERFORMS THE FOLLOWING TESTS TO ASSURE THE SECOND STAGE REGULATOR DOES NOT INTERNALLY LEAK: 1) CONTAMINATION IS REDUCED/MINIMIZED BY CLEANING ALL THE REGULATOR INTERNAL DETAILS AND OXYGEN PASSAGEWAYS TO 15 PSID RM EPA. THE TEST FACILITY HARDWARE AND GASES ALSO MET THIS REQUIREMENT. 2) THE REGULATOR INTERNAL LEAKAGE IS TESTED DURING ACCEPTANCE TEST AT 2400 PSS INLET.</p> <p>PDA TESTING - THIS ITEM IS INTERNAL LEAKAGE TESTED ON THE SGP. WITH THE SGP BOTTLES PRESSURIZED TO 6000-6200 PSID AND THE SGP SIGNALS REMAIN ACTIVATED TO THE ON POSITION. THE DIAPHRAGM PRESSURE ON THE REGULATOR IS SET TO 4.06-5.20 PSID. THE DIAPHRAGM ASSEMBLY LEAKAGE IS 10 SCC/MIN O2 AS MEASURED WITH A CAPMAN FLOWMETER FROM THE REGULATOR OUTLET. ALL DESI TUBINGS, INTERFACING METS, AND TEST LINES THAT CONNECT TO EITHER HIGH OR LOW PRESSURE CIRCUITS ARE CLEANED TO 100 3150 LEVEL RMBA. THE ITEM IS PROTECTED FROM CONTAMINATION BY PACKING 15 MICRON ABSOLUTE DRY FILTERS UPSTREAM OF THE TEST ITEM.</p>

CIL
CRITICAL ITEMS LIST
FILE: CIL3/8

NAME P/N QTY	CRIT	FAILURE MODE & CAUSE	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
02 PRESSURE REGULATOR, 2ND STAGE ITEM 2130 SV710475- 13 (1) FC178-2 *	2/10	2130FFM01B; INTERNAL GAS LEAKAGE, FAILS OPEN.		<p>CERTIFICATION TEST - ITEM COMPLETED THE FOLLOWING CYCLE TESTS DURING 5/85: ON/OFF ACTUAL 1025, SPEC 3001; NO FLOW HOURS ACTUAL 904, SPEC 10; BLEEDING ACTUAL 112, SPEC 35. NO CLASS I ENGINEERING CHANGES HAVE BEEN INCORPORATED SINCE THIS CONFIGURATION WAS CERTIFIED.</p> <p>C. INSPECTION - ALL DETAILS, GAGES AND TEST FACILITIES ARE CLEANED AND INSPECTED TO MEET EN88A TO PRECLUDE CONTAMINATION CLOGGING. THE O-RING AND LIP SEALS ARE 100% INSPECTED FOR SURFACE CHARACTERISTICS BY THE REGULATOR VENDOR. DETAILS, INCLUDING THE O-RING GROOVES AND SEALING SURFACES, ARE 100% INSPECTED PER DRAWING DIMENSIONS AND SURFACE FINISH CHARACTERISTICS. DETAILS ARE MANUFACTURED FROM MATERIAL WITH CERTIFIED PHYSICAL AND CHEMICAL PROPERTIES, THE RUNNING AND FINAL TORQUE OF ALL THREADED CONNECTIONS ARE VERIFIED BY VENDOR AND DEAS INSPECTORS. A TRIAL ASSEMBLY IS RUN ON ALL DETAILS AND THEN THEY ARE VISUALLY INSPECTED. THE DEMAND VALVE PINPLE AND BALANCE STEM ARE MANUALLY DEPRESSED DURING ASSEMBLY TO ASSURE FREE MOTION.</p> <p>D. FAILURE HISTORY - MEMO-213-001 (7-11-80) INTERNAL LEAKAGE DUE TO MISMACHINED BALANCE STEM DIME. ASSEMBLY PROCEDURES WERE CHANGED TO INCLUDE A TRIAL ASSEMBLY. M-213-004 (2-12-81) INTERNAL LEAKAGE DUE TO INCORRECT BACKUP RING MATERIAL. UNIT WAS FURTHER DAMAGED BY OVER PRESSURE DUE TO LACK OF RELIEF VALVES IN THE TEST FACILITY. THE REGULATOR DRAWINGS AND PROCEDURES WERE CHANGED TO INCORPORATE THE PROPER BACKUP RING. THE TEST FACILITY WAS CHANGED TO INCORPORATE RELIEF VALVES. MEMO-213-005 (2-24-81) INTERNAL LEAKAGE DUE TO ROUGH DEMAND VALVE BORE SEALING SURFACE FINISH. ALL CRITICAL BLENDING AND SEALING SURFACES ARE INSPECTED AT 2X MAGNIFICATION. J-EMU-213-009 (10-8-82) INTERNAL LEAKAGE DUE TO FLASHING ON THE BALANCE STEM O-RING. O-RING AND SEAL YOLD WERE REPLACED.</p> <p>E. GOING TURNDOWN - TESTED PER FEHU-R-001, SOP SERVICING FOR FLIGHT, SHUTOFF VALVE INTERNAL LEAKAGE.</p>

CIA
 CRITICAL ITEMS LIST
 FILE: CILS/1

NAME P/N RTY	CRIT	FAILURE MODE & CAUSE	FATIGUE EFFECT	RATIONALE FOR ACCEPTANCE
O2 PRESSURE REGULATOR, 2ND STAGE ITEM #150 SV770675- 15 111 PC170-3	2/10	ELSDFN010; INTERNAL GAS LEAKAGE, VALVE OPEN.		F. OPERATIONAL USE - CREW RESPONSE - EVA: SINCE EVA TERMINATION IS REQUIRED AS SOON AS SOP IS FLOWING, CREW WOULD ABORT EVA WHEN EXCESSIVE SOP RATE IS DETECTED. SPECIAL TRAINING - STANDARD ENU TRAINING COVERS THIS FAILURE MODE. OPERATIONAL CONSIDERATIONS - EVA CHECKLIST PROCEDURES VERIFY HUMWARE INTEGRITY AND SYSTEMS OPERATIONAL STATUS PRIOR TO EVA. FLIGHT RULES DEFINE GO/NO GO CRITERIA RELATED TO ENU PRESSURE INTEGRITY AND REGULATION. FLIGHT RULES DEFINE ENU AS GO/NO FOR LOSS OF OPERATIONAL SOP. REAL TIME DATA SYSTEM ALLOWS GROUND MONITORING OF ENU SYSTEMS.