

NAME P/N QTY	CELL	FAILURE MODE & CAUSE	FAILURE EFFECT	RATIONALE FOR ACCEPTANCE
<p>PRESSURE TRANSDUCER, 2/10 ITEM 215 14770473-4</p>		<p>DESIGN: leakage at pressure sensitive interface.</p> <p>CAUSE: Failure of material.</p>	<p>EMO ITEM: Leakage path between SOP tanks and strain gauge cavity.</p> <p>G/E INTERFACE: SOP oxygen tank pressurizes the strain gauge cavity between pressure sensitive interface and electrical feed through connector. Loss of SOP transducer output.</p> <p>MISSION: None for single failure.</p> <p>CELL/VEHICLE: None for single failure. Possibility loss of oxygen for second failure (leakage) of electrical feedthrough connector and potential ignition of non metallics in electronic cavity.</p>	<p>A. Design - In the event of diaphragm leakage, the strain gauge cavity is designed to contain the pressure. The minimum calculated factor of safety to the strain gauge cavity is 1.35 against the 2,400 psi pressure and 1.11 against the 9000 psi requirement. The stress of 45,800 psi in the loop stress in the wall of the four-pin header shell. This analysis has been substantiated by a strain gauge cavity test run to 45,800 psi without failure. For a minimum wall thickness this results in a pressure capability of at least 10,942 psi. The header shell material is 1018 carbon steel, which was selected for its compatibility with the glass scale at the connector pins. One side of the header shell is mechanically sealed and the other is gatted, thus the shell will be (1018 carbon steel) not subject to corrosion. The weld joints, 17-4 PH stainless to 1018 carbon steel and 17-4 PH are also not known to corrode in a dry atmosphere. The gold plated brass connector pins are similarly corrosion resistant.</p> <p>B. Test - Component Acceptance Test - The electrical feedthrough is pressure tested as a detail part of the vendor (Kulite Semiconductor, Inc.). This test consists of pressurizing the feedthrough with 9000 psi water or alcohol and holding it for 1 minute after which a helium test test is done. The maximum helium leakage allowed is 1 x 10<sup>-6</sup> cc/psi at 1 atmosphere. The feedthrough is subsequently welded into the pressure transducer. It is not possible to pressure test this unit. PDA Testing: It is not possible to pressure test the feedthrough connector during the PDA test.</p> <p>Certification Test - The pressure transducer completed the 15 year structural vibration and shock certification requirement during 10/81. Qualification Test - A burst test on the electrical feedthrough was done on 12/11/85. This test unit held a pressure of 15,000 psi, without any signs of leakage (design requirement is 9000 psi).</p> <p>C. Inspection - The pressure sensing diaphragm stainless steel 17-4 PH, is</p>

8

EMO CHEMICAL  
ITEM LIST  
Page 1

CD)  
EMU CRITICAL ITEMS LIST

OPERATOR RESPONSIBLE / /

AMT 1991

Page: 2  
Date: 06/08/90

NAME  
P/N  
QTY

CDIT

FAMILY  
MODE #  
LARGE#

FAILURE EFFECT

REMEDIAL FOR ACCEPTANCE

2/04

DISPENS

verified by vendor inspection of the external construction  
stick). The first three welds from the pressure casing slip  
are X-ray inspected; the last weld is not. Engineering  
change 4200-499 required that all four welds be X-ray  
inspected (presently 3 of the existing 7 flight units meet  
this requirement). Engineering change 4200-499-1 is in  
process and will downgrade the five aircraft units to  
nonflight status, after these units are depressurized.

G. Failure History -  
None.

H. Ground Maintenance -  
Tested per SEMU-1-001, RCP transmitter calibration.

I. Operational Use -

Operational Effects - Crew Response -  
QVA: When QVA termination should begin at 2000 or 2400 to  
flaring, crew response is as normal termination. No  
further response is necessary since engine failure is  
indicated by crew as ground.

Operational Considerations -

Reference (see/where flight rules define QVA as test for  
loss of operational RCP.  
QVA checklist and PD) procedures verify hardware integrity  
and system operational status prior to QVA.  
Real Time Data System allows ground monitoring of QVA  
systems.

391

SEMU-1-001  
REV. 02  
CHARGE 1